

Recommended Guideline for a Shut Down (BRITA water filter)

Instructions for use of BRITA Professional cartridges for longer periods of non-use (source: BRITA Professional Filter Products - Taunusstein, Germany)

General information:

BRITA recommends that filter systems and cartridges should not be used for a long period of time without operation. In case of a longer period of non-use of the filters, such as in the case of company holidays, seasonal or other temporary closures, are as follows safety instructions must be observed:

PURITY and PURITY C

- During periods of non-use, pipe-bound water filters should be connected to the water pipe remain connected.
- Do not open the filter.

BRITA recommends flushing the filter cartridges with the quantities of water indicated in the tables below,

PURITY C	Flushing volume	
	2-3 days	more than 3 weeks
Non-use period	2-3 days	more than 3 weeks
PURITY C 50	2 litres	20 litres
PURITY C 150	3 litres	30 litres
PURITY C 300	6 litres	60 litres
PURITY C 500	10 litres	100 litres
PURITY C 1100	18 litres	180 litres
PURITY C 1000 AC	1 litres	10 litres
PURITY C Min up	0 litres	0 litres
Cartridge change latest 12 months after installation or reaching capacity, whatever comes first		

PURITY (Quell ST / Steam/Clean)	Flushing volume	
	2-3 days	more than 3 weeks
Non-use period	2-3 days	more than 3 weeks
PURITY 450	6 litres	30 litres
PURITY 600	12 litres	60 litres
PURITY 1200	24 litres	120 litres
Cartridge change latest 12 months after installation or reaching capacity, whatever comes first		

If you have further questions, please don't hesitate to contact your local Melitta Professional Service Team or your sales contact / distributor.